Public Water System Sample Collection Analysis Report

Public Water System ID #: TX0910033

Report to:
OAK RIDGE SOUTH GALE WSC
PO BOX 1263
DENISON, TX 75021-1263

Collection Date: 9/6/2023

Water analyses are required by law (30 TAC \$290, THSC \$341.0315). I acknowledge that the sampling technician has been accompanied during sampling and that the sample has been collected from the correct location indicated on this form. Water systems are responsible for all laboratory fees. Falsification of this form or tampering with water samples is a crime punishable under state and federal law. Refusing to sample, including refusing to sign this form, will result in a monitoring and reporting violation(s), possible enforcement, and fines.

JACK FORBES

WATER SYSTEM REPRESENTATIVE

						M' X							
					CHRISTIN	A NIXON							
					SAMPLING	TECHNICIAN							
SAMPLING	G LOCATION	A .											
FACIL	ITY ID: EPO	01	FACILITY LOCATION: 382 E FM 120, DENISON SAMPLE LOCATION: PUMPHOUSE					LAT: N 33.75255 LONG: W -96.511465					
SAMPLE	POINT: TRT	-TAP											
TAP FLUSHING - START: 9:48			FREE CHLORINE RESIDUAL: mg/L					TEMPERATURE: 86 'F					
END: 9:54			TOTAL CHLORINE RESIDUAL: 3.18 mg/L					pH: 7.8					
TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER		PRESERVATION			AMPLE ERIOD	LAB	SAMPLE	PRIOR	- COMPLI- ANCE	
9:54:30	2334222	NITRATE	100 ML PLASTIC OR	GLASS	COOL 4C		Y	R2023	LCRA	RT	N	YES	
SAMPLING LOCATION FACILITY ID: DS01 SAMPLE POINT: DBP2-01 TAP FLUSHING - START: 9:33 END: 9:46			FACILITY LOCATION: DISTRIBUTION SYSTEM SAMPLE LOCATION: 382 E FM 120, DENISON FREE CHLORINE RESIDUAL: mg/L					LAT: N 33.75477 LONG: W -96.511007 TEMPERATURE: 86 'F					
			TOTAL CHLORINE RESIDUAL: 2.88 mg/L										
TIME	SAMPLE	ANALYSIS TYPE	CONTAINER		PRESERVATION			AMPLE ERIOD	LAB	SAMPLE TYPE		- COMPLI- ANCE	
9:46:22	2355869	DBP2	2-40 ML CLEAR/2-60	ML AMBER	Na2S2O3/NH4C	L, COOL 4C, DARK	30	22023	LCRA	RT	N	YES	
	G LOCATION		FACILITY	LOCATION:	DISTRIBUTION	SYSTEM	attend from the synthesis teach response you receive of the	nhoromięzawacju		LAT: N 3	3.7572	293	
SAMPLE	POINT: DBP	2-02	SAMPLE LOCATION: 5170 FM 120, DENISON					LONG: W -96.434383					
TAP FL	USHING - ST	TART: 9:13	FREE CHLORINE RESIDUAL: mg/L					TEMPERATURE: 84 'F					
		END: 9:23	TOTAL CHLORINE RESIDUAL: 2.62 mg/L					pH: 7.8					
TIME	SAMPLE	ANALYSIS TYPE	CONTAINER		PRESERVATION			AMPLE ERIOD	LAB	SAMPLE TYPE	PRIOR	- COMPLI~ ANCE	
9:23:39	2355870	DBP2	2-40 ML CLEAR/2-60	ML AMBER	Na2S2O3/NH4C	L, COOL 4C, DARK	39	22023	LCRA	RT	N	YES	

FOR MORE INFORMATION: Public water systems may view their water system information including sampling schedules and sample results by visiting the State of Texas Drinking Water Watch website at the following address: http://dww2.tceq.texas.gov/DWW/

Regulations governing sample scheduling and collection are available upon request from the Public Drinking Water Section of the Texas Commission on Environmental Quality. Phone: (512) 239-4691 Email: PWSCHEM@tceq.texas.gov Website: http://www.tceq.texas.gov

Lab fee schedule can be found at the following address: www.tceq.texas.gov/drinkingwater/chemicals/sample_collection/costestimate#Lab-fees

distribution of the constitution of the state of the dispression of the second state o

and the company of th